ASSET DATA DICTIONARY DEFINITION DOCUMENT (AD4)
L74622 – HV CABLES

Document Number: **CRL1-XRL-Z3-ADDSD-CR001-50164**

Document Revision: **11.0**

Learning Legacy Document

Document History:

Revision:	Date:	Prepared by:	Checked by:	Authorised by:	Reason for Issue:
000	11-Sep-2012	[redacted]	[redacted]	[redacted]	First Issue
2.0	11-Oct-2013	[redacted]	[redacted]	[redacted]	Standardisation of Attribute Names and New Branding
3.0	03-Jun-2014	[redacted]	[redacted]	[redacted]	Asset Tag Identification Section Updated
4.0	24-Jun-2014	[redacted]	[redacted]	[redacted]	New attribute added IMP-0004.130
5.0	19-Sep-2014	[redacted]	[redacted]	[redacted]	Approvals Added Consultations Removed
6.0	17-Dec-2014	Kemi Olawale	[redacted]	[redacted]	Replaced Image Attributes Added
7.0	27-Aug-2015	[redacted]	[redacted]	[redacted]	Labelling Section Updated
8.0	11-May-2016	[redacted]	[redacted]	[redacted]	Attributes added
9.0	30-Aug-2016	[redacted]	[redacted]	[redacted]	Attribute Added
10.0	20-Apr-2017	[redacted]	[redacted]	[redacted]	Attribute Replaced
11.0	25-Apr-2017	[redacted]	[redacted]	[redacted]	LRS Codes Updated

Document uncontrolled once printed. All controlled documents are saved on the CRL Document System

© Crossrail Limited **RESTRICTED**

This document contains proprietary information. No part of this document may be reproduced without prior written consent from the chief executive of Crossrail Ltd.

Learning Legacy Document

Document uncontrolled once printed. All controlled documents are saved on the CRL Document System

© Crossrail Limited RESTRICTED

Contents

1 Introduction 4
1.1 Asset Details 4
1.2 Description 4
1.3 Related Functions 4
2 Asset Tag Identification Rules 4
2.1 Example Images 5
3 Attributes 6
3.1 Generic Attributes 6
3.2 Class Specific Attributes 6
4 Performance Data 9
5 Labelling 9
6 Other Information 9
7 Reference Material 9
8 Crossrail Technical Approvals 10

Learning Legacy Document

Document uncontrolled once printed. All controlled documents are saved on the CRL Document System
© Crossrail Limited RESTRICTED

1 Introduction

1.1 Asset Details

Class Code:	L74622
Class Name:	HV cables
Class Lineage:	Construction Products>Services>Electric power and lighting services products> Distribution devices>Conductors>HV cables

1.2 Description

HV cables, also referred as high-voltage cables, are used for electric power transmission at high voltage. High voltage is defined as any voltage over 1000 volts.

1.3 Related Functions

All information on the configuration of asset classes (L-Class) to functions is contained within the latest revision of the Asset Data Dictionary Master Configuration document (eB ref: CRL1-XRL-Z3-ADDSD-CR001-50186)

2 Asset Tag Identification Rules

Assets will be identified as required by the Asset Identification Standard (CRL1-XRL-O6-STD-CR001-00031) in the following format:

<LCS Code>-<Function Code>-<Incremental number to ensure uniqueness>

e.g. CR076-BAF-12345

Information and guidance on the standard naming convention for all asset classes is contained within the latest revision of the Asset Naming Convention Document (eB ref: CRL1-XR1-Z3-ADDSD-CR001-50413).

Learning Legacy Document

Document uncontrolled once printed. All controlled documents are saved on the CRL Document System

© Crossrail Limited RESTRICTED

2.1 Example Images

Learning Legacy Document

Document uncontrolled once printed. All controlled documents are saved on the CRL Document System
© Crossrail Limited RESTRICTED

3 Attributes

3.1 Generic Attributes

All Classes of assets will have a set of Generic Attributes for which data is collected without exception. Full details relating to these assets can be found at:

AD4 – Generic Attributes CRL1-XRL-Z3-ADDSD-CR001-50069

3.2 Class Specific Attributes

Below is a table of the further specific attributes which are associated with this asset class.

Attribute Name	Base Unit or Formula	Value Type (See Below)	Decimal Places (nu Only)	Defined Values List (pd only)	Description
Diameter (Millimetres)	Millimetres	NU	0		Diameter of the conductor
Full Load Current (Amps)	Amps	NU	0		Current rating or current-carrying capacity is defined as the maximum amount of electrical current a conductor or device can carry before sustaining immediate or progressive deterioration; also described as, capacity It is the RMS electric current which a device or conductor can continuously carry while remaining within its temperature rating.
Number of Cores (#)	#	NU	0		A cable core is the portion of an insulated cable lying within the protective covering or coverings.
Working Voltage (Volts)	Volts	NU	0		Working Voltage is defined as the maximum safe operating voltage of the connector over its rated frequency range and atmospheric conditions.
Cross Sectional Area (Square Millimetres)	Square Millimetres	NU	0		Cross sectional Area of HV cable
Core Material		PD		Aluminium Copper	Material of wires within cabling

Document uncontrolled once printed. All controlled documents are saved on the CRL Document System

© Crossrail Limited RESTRICTED

Learning Legacy Document

Attribute Name	**Base Unit or Formula**	**Value Type** (See Below)	**Decimal Places** (nu Only)	**Defined Values List** (pd only)	**Description**
Insulation Class		PD		LSOH XLPE PVC Paper	Material of insulation layer around wires
From Meterage (Metres)	Metres	NU	2		The Meterage (Chainage) of the start point of the asset. To be populated only when the start of the asset is located on track.
To Meterage (Metres)	Metres	NU	2		The Meterage (Chainage) of the end point of the asset. To be populated only when the end of the asset is located on track.
LRS Code		PD		C.EB C.EB.CRW5 C.EB.CR1 C.EB.CR7 C.EB.TBC C.WB C.WB.CRW9 C.WB.CRW6 C.WB.CR2 C.WB.CR5 C.WB.TBA C.WB.TBB CNE.EB CNE.WB CSE.EB CSE.EB.CR11 CSE.WB CSE.EB.CR13 CSE.WB.CR15 Non Track	The Crossrail Linear Referencing Standard code (CRL1-XRL-O6-STD-CR001-00026) where the asset is located. When the asset is not located on track then non track should be selected. The LRS codes are as follows: C.EB - Central Section Eastbound C.EB.CRW5 - Crossover between W5 and W4 Points C.EB.CR1 - Crossover between C1 and C4 Points C.EB.CR7 - Crossover between C7 and C8 Points C.EB.TBC - Turnback C C.WB - Central Section Westbound C.WB.CRW9 - Crossover between W9 and W8 Points C.WB.CRW6 - Crossover between W6 and W3 Points C.WB.CR2 - Crossover between C2 and C3 Points C.WB.CR5 - Crossover between C5 and C6 Points C.WB.TBA - Turnback A C.WB.TBB - Turnback B CNE.EB - Central Section North East Spur Eastbound CNE.WB - Central Section North East Spur Westbound CSE.EB - Central Section South East Spur Eastbound CSE.EB.CR11 - Crossover between C11 and C12 Points CSE.WB - Central Section South East Spur Westbound CSE.EB.CR13 - Crossover between C13 and C14 Points CSE.WB.CR15 - Crossover between C15 and C16 Points Non Track - Non Track Assets

pd = Predefined List (Listed Values Only)

Document uncontrolled once printed. All controlled documents are saved on the CRL Document System

© Crossrail Limited RESTRICTED

Learning Legacy Document

nu = Numeric (dp and number format can be stipulated)
ch = Free text (Max 255 Characters)
da = Date (dd-mm-yyyy)
me = Memo (Free text 1GB Limit)

Learning Legacy Document

Document uncontrolled once printed. All controlled documents are saved on the CRL Document System

© Crossrail Limited RESTRICTED

4 Performance Data

This section is to be used to specify the performance data to be gathered from this Class of asset when in operation. To be populated once the performance measures have been agreed with the Infrastructure Managers.

5 Labelling

Information and guidance on the standard labelling convention for all asset classes is contained within the latest revision of the Asset Naming and Labelling Convention Document (eB ref: CRL1-XR1-Z3-ADDSD-CR001-50413).

6 Other Information

Not Applicable

7 Reference Material

- Asset Data Dictionary Master Configuration - CRL1-XRL-Z3-ADDSD-CR001-50186
- Asset Identification Standard - CRL1-XRL-O6-STD-CR001-00031
- AD4 – Generic Attributes - CRL1-XRL-Z3-ADDSD-CR001-50069
- Asset Naming Convention Document - CRL1-XR1-Z3-ADDSD-CR001-50413

Learning Legacy Document

Document uncontrolled once printed. All controlled documents are saved on the CRL Document System

© Crossrail Limited RESTRICTED

8 Crossrail Technical Approvals

Name	Role	Date
[redacted]	Lead Mechanical & Electrical Plant (MEP) Engineer	19-Sep-2014

Learning Legacy Document

Document uncontrolled once printed. All controlled documents are saved on the CRL Document System
© Crossrail Limited RESTRICTED